


COMPRESSIVE STRENGTH OF SHOTCRETE 530



0.5 hour	0.6
1 hour	4.1
1.5 hours	11.5
2 hours	15
2.5 hours	18.8
3 hours	19.9
3.5 hours	22.5
4 hours	24.3
4.5 hours	24.5
5 hours	24.8

TEST PROGRAMME PREPARED BY:
DR K.E. Hassan - Civil Engineering Materials Unit (CEMU)
School of Civil Engineering, University of Leeds

Natural Cement Distribution Ltd.
 15 Fountain Parade, Mapplewell, Barnsley. S75 6FW
 Tel: 01226 381133 Fax: 01226 381177 www.naturalcement.co.uk