REGULATION 31(4)(A) OF THE WATER SUPPLY (WATER QUALITY) REGULATIONS 2016 SI No 614 (AS AMENDED)& THE WATER SUPPLY (WATER QUALITY) REGULATIONS 2018 (WALES) SI No 647

APPROVED PRODUCT CHANGE ACCEPTANCE

Product name/designation	NATCEM AC
Approval Holder (Name & Address)	Natural Cement Distribution Ltd 10-11 Fountain Parade, Mapplewell, Barnsley, South Yorkshire, S75 6FW, United Kingdom
Instructions for Use	Title: Natcem AC Issue: 4 Issue Date: 16/09/2024
Agreed Change	Change to curing conditions, materials of construction and update to IFU.
DWI Ref Number	56/4/840

The Secretary of State for Environment, Food and Rural Affairs in respect of relevant water suppliers[1] whose area of supply is wholly or mainly in England, and the Welsh Ministers in respect of relevant water suppliers whose area of supply is wholly or mainly in Wales, in exercise of their powers under Regulation 31(4)(a) of the Water Supply (Water Quality) Regulations 2016 and Regulation 31(4)(a) of the Water Supply (Water Quality) Regulations 2018 (Wales) respectively hereby accept changes made in respect of the product detailed above, in accordance with the following Conditions of Use & Approval.

CONDITIONS OF USE & APPROVAL

The above named product is approved for application in England and Wales[2] by a water supply company for public water supply purposes subject to the following conditions:

1. Water undertakers and water supply licensees shall be provided with a copy of the Instructions for Use (IFU) detailed above and use of the approved product must be in accordance with the IFU.

2. The Drinking Water Inspectorate (DWI) must be notified, in advance and in writing, by the approval holder detailed above, in respect of any **further** change(s) in –
   a) The Instructions for Use
   b) The formulation of the approved product, including change in source or identity of raw materials
   c) The manufacturing process, including location of manufacture
   d) The designation of the approved product
   e) The name, address or ownership of the organisation holding the approval

   Failure to notify such further changes will result in approval being withdrawn.

3. The producer shall ensure that the product is tested for conformity with its formulation, and the source or identity of its raw materials, at such intervals and by such persons, as may be determined by the Authorities. The results of such testing shall be sent to DWI.

4. The use of either the Drinking Water Inspectorate or Defra logos, in respect of any approved product (including on the product or in editorial or advertising/trade copy) is not permitted.

5. The following changes to any product specific condition(s) apply – ***Product must be set and cured for a minimum of 240 minutes at a minimum temperature of 0°C in accordance with the manufacturer's Instruction for Use***

6. This letter replaces any Approval Letter/Confirmation issued previously for this product

Signed by authority of the Secretary of State
and the National Assembly for Wales

Date of Issue: 20/01/2025
Date of Expiry: 19/01/2030

Marcus Rink
Chief Inspector of Drinking Water
England and Wales

[1] Relevant water suppliers shall include water undertakers, water supply licensees and inset appointees.
[2] Separate approval arrangements apply in Scotland and Northern Ireland